



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

July 8, 2010
Subject: **Township D**
Federal Project No: SB-ME-98(007)
State Pin No: 008670.10
Amendment No. 2

Dear Sir/Ms:

Make the following change to the bid document:

In the Bid Book {after SPECIAL PROVISION, SECTION 606, GUARDRAIL, (Timber Rail)}, ITEM 606.611 TIMBER GUARDRAIL DETAIL, **CHANGE** all references to "200 mm (square) #2 CEDAR" to read "**150** mm (square) #2 CEDAR". Make this change in pen and ink.

The following question has been received:

Question: On page 1 of Special Provision 606 Guardrail Timber Rail call for 6" x 6" x 6', on 606.611 Timber Guardrail detail calls for 8" x 8" x 6' post. Which is it?

Response: 150mm X 150mm is correct, please see the above pen and ink change.

Consider this change and information prior to submitting your bid on July 14, 2010.

Sincerely,

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER